

## COMMON CONTROL SYSTEM ABBREVIATIONS

Abbreviation	Usually Means...
AI	Analog In
AO	Analog Out
ATS	Automated Temperature System
BACNet	Building Automation and Control Networks
BAMCS	Building Automation Management Control System
DDC	Direct Digital Control
DGP	Data Gathering Panel
DI	Digital In
DO	Digital Out
EIP	Event Initialed Program
HMI	Human Machine Interface
N.C	Normally Closed
N.O.	Normally Open
PLC	Programmable Logic Controller
SCADA	Supervisory Control and Data Acquisition
TIP	Time Initialed Program
UI	Universal Input
UO	Universal Output

*Visit [www.HVACnotebook.com](http://www.HVACnotebook.com) for more lists and time-saving spreadsheets.*