

Project Title: Sample Project
 Project ID: 130206
 Project Manger: T.M.

Prepared By: C.P Sheet: 1 of 1
 Checked By: C.P. Date: 8/26/15

Annual Cooling Cost Estimate With SEER & Comparison

Notes:
 Annual Operating Cost Comparison with different SEER's

| | AC Unit #1 | AC Unit #2 | | Remarks |
|--------------------------------|----------------|----------------|---------|---------------------|
| Cooling Capacity: | 5.0 | 5.0 | Tons | |
| Efficiency in SEER: | 13.0 | 15.0 | SEER | |
| Operating hours per year: | 2,000 | 2,000 | hours | Cooling Season Only |
| Electricity cost per kWhr: | \$0.25 | \$0.25 | \$/kWhr | |
| Annual Operating Cost = | \$2,308 | \$2,000 | | |

| | |
|--|--------------|
| Annual Savings: AC Unit #1 vs. AC Unit #2 = | \$308 |
|--|--------------|

| | | |
|------------------------------|---------------|---------------|
| Cost per hour per ton | \$0.23 | \$0.20 |
|------------------------------|---------------|---------------|

REMARKS:
 Your Notes Here.